

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20191463  
Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sanitary Sewer Construction Inspection</b>	John Jackson	Passed	Tuesday, September 17, 2019

Informational:

1 Misc

Informational:

2 Misc

Contractor installed approximately 60' of 6" SDR-26 Sewer main. Contractor end installation at proposed build structure with a Fernco Hard back coupling. 2/45 degree 6" bends where install on line 55" piece of 6" is between the 2/45 degree bends.

**Comments:**