

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191897
Address: 3200 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|----------------|----------|-----------------------------|
| DE - Storm - Material Verification | Ronald Paynter | Passed | Tuesday, September 17, 2019 |

Informational:

1 Misc

Storm boxes, lids, and RCP (reinforced concrete pipe) were manufactured by Forterra Pipe & Precast. The steps used in the boxes are PS-2-PF. Manhole castings for the storm are EJ 1502A. RCP's are 36, 54 and 66 inches wide. HDPE storm pipes were manufactured by Advance Drainage System. HDPE I've and model are 15650020IBL, 18650020IBL, 24650020IBL, 30650020IBL and 36650020IBL. RP 9-17-19

Comments: