

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20171770
Address: 1801 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Tuesday, September 17, 2019

Corrective Action Required:

1	Misc	- used as a model sales office. recall for Final inspection when office/ sales office is removed and turned back into a garage. ** Missing fire separation from garage to living space. Door sized opening framed and insulated but not sheetrocked. ** Submit As-graded Plot Plan.
---	------	--

Comments: