

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190589
Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 18, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT:
RETURN AIR CHASE AT CORRIDOR A201: 1ST LAYER 5/8" GWB; **2ND LAYER 5/8"**
GWB;

RETURN AIR CHASE AT CORRIDOR A301: 1ST LAYER 5/8" GWB; **2ND LAYER 5/8"**
GWB;

Comments: