

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Coliform Test 2	John DiMauro	Partial	Wednesday, September 18, 2019

Informational:	
1 Misc	I met Daniel with Redford Construction on site and collected the day 2 water samples for the site. I delivered the samples to Keystone Lab. We will know the results in 24 hours.

Comments: