

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191001	Date:	September 18, 2019
Project Title:	HT SOLUTIONS - ADDITION	Applicant:	
Location:			
1440 SE BROADWAY DR, LEES SUMMIT, MO 64081		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	F-2	KANSAS CITY, MO 64116	
Description:	ADDITION TO EXISTING FACTORY		
Construction Type:	Type IIB (Unprotected)	Primary:	(913) 888-0647
Map Page:	195R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

A hydrostatic test will be required. Call (816)969-1300 to schedule.

2. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

(Informational Purposes)

System to remain operational in existing building during construction.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.