

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182609
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 18, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" GWB RATED ASSEMBLY AT STAIRWELLS:

NORTH STAIR: BASEMENT LEVEL 1ST LAYER AT INTERIOR + BETWEEN JOISTS AT BACKSIDE;

Comments: