

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191834

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Thursday, September 19, 2019

Corrective Action Required:

1	Misc	INSPECT ONLY: 112-113;116-118; 122; 124-126; 129-137; 139-149
---	------	---

- FASTEN STUDS TO TRACKS
- HAVE ENGINEER ADDRESS FRAMING CAPACITY TO SUPPORT DEAD WEIGHT ABOVE LARGE WALL OPENINGS
- INSTALL BLOCKINGS FOR RESTROOM GRAB BARS
- PROTECT PLUMBING AT MEN RESTROOM VANITY WALL

Comments: