

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191464
Address: 1112 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Thursday, September 19, 2019

Corrective Action Required:

1	DCM2 Erosion Control	-REINSTALL EROSION CONTROL ALONG THE STREET -PROVIDE MIN 3/4" GRAVEL FILTER AT LOT ENTRANCE
---	----------------------	--

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Comments: