

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20183200  
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Steve Quaid	Passed	Thursday, September 19, 2019

Informational:

1	Miscellaneous Correction	Inspected fur down ceilings in units: A135-passed A136-Hole in front closet rated wall-repaired A137-passed A138-Needed fire stopped at alarm wire-repaired A139-passed A140-passed A141-passed A142-passed A143-passed A144-passed A145-passed A146-passed A147-Hole in rated ceiling of master bath south wall - repaired A148-Needed fire stop in kitchen ceiling at fire alarm wire-repaired; Pantry light not wired-repaired; Bathroom rated ceiling above tub had a hole-repaired; Closet rated ceiling above condensate line had a hole-repaired
---	-----------------------------	---

**Comments:**

