

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190221
Address: 2401 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	John DiMauro	Passed	Thursday, September 19, 2019

Informational:
1 Misc

PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.

I was on site last week to do a pre inspection for the ADA section of the sidewalk. There was damage to the ADA ramp and it was out of compliance therefore it had to be replaced. The curb cut for the ADA ramp also has damage and needs replaced.

The contractor is going to pour the sidewalk today and leave the ADA ramp to pour at a later date.

Comments: