

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20184050  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 1</b>	John DiMauro	Passed	Friday, September 20, 2019

Informational:  
1 Misc On site with Daniel from Redford Construction. We collected the day 1 samples for the water line and delivered them to Keystone Labs. We will know the results is 24 hours.

Informational:  
2 Misc The day 1 bacteria samples passed. The results from Keystone Labs are uploaded into the system.

**Comments:**