

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20183262  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Brandon Kalwei	Partial	Friday, September 20, 2019

Partial Correction:

1            Misc

OK TO COVER WHEN READY TRENCHED ELECTRICAL CONDUIT AT: THREE 4" + TWO 1-1/4" TO (A); SAME CLUSTER OF CODUIT APPROVED 140 FEET SOUTH TO 90 EAST TO (C); + 50' EAST TO (E); THREE 4" FROM (C) TO (D); THREE 4" + TWO 1-1/4" FROM (E) TO (F); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (F) TO (G); ONE 1-1/4" FROM (H) TO (I); ONE 1-1/4" + TWO 3/4" FROM (I) TO (J); ONE 3/4" STUBBED EAST FROM (J); TWO 3/4" FROM (J) TO (K); TWO 3/4" FROM (K) TO (L); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + TWO 3/4" FROM (M) TO (N) WITH ONE STUBBED WEST AT (M) FOR SITE LIGHTING; TWO 4" + TWO 1-1/4" + ONE 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (N) TO (P); TWO 1-1/4" + ONE 3/4" FROM (Q) TO (S); ONE 3/4" FROM (Q) TO (R); ONE 3/4" FROM (T) TO (U); 3/4" CONDUIT AT CONSTRUCTION ENTRANCE APPROVED; 3/4" CONDUIT 110 FEET FROM SE CORNER OF THE BUILDING; REMAINDER OF RUN TO VAULT AT (W); THREE 4" + TWO 1-1/4" FROM (M) TO (X); THREE 4" + THREE 1-1/4" FROM (X) TO (Y); FOUR 4" + ONE 3" FROM (Z) TO (AA); ONE 3/4" AT ISLAND @ (W); ONE 3/4" FROM (X) TO (BB); ONE 3/4" FROM (X) TO (CC); FOUR 4" + ONE 3" FROM (CC) TO (DD); THREE 4" + TWO 1-1/4" FROM (EE) TO (FF); TWO 3/4" FROM (GG) TO (HH); ONE 1-1/4" + ONE 3/4" FROM (HH) TO 60' WEST @ (II); THREE 4" + ONE 1-1/4" FROM (JJ) TO (KK); THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (MM) - THEN 30' EAST; THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (NN) 60' SOUTH; THREE 4" + ONE 1-1/4" ORIGINATING FROM (KK) EXTENDED TO (NN);

REMAINDER OF CONDUITS FROM E/SE CONVERGING ON LOCATION OF BOX TO BE INSTALLED AT (II); FOUR 4" + ONE 3" FROM XFMR LOCATION TO W END OF BLDG 4; THREE 4" FROM E END OF BLDG 4 NORTH 35', THEN S 15' TO (OO); FROM MONUMENT SIGN AT NORTH ENTRANCE TWO 3/4" TO 30' SE & TWO 3/4" TO 30' SW; FOUR 4" + ONE 3" FROM (OO) TO (PP) & SECONDARY CONDUITS AT (PP); THREE 4" + TWO 1-1/4" FROM (A) TO 24' N; FOUR 4" + ON 3" FROM NW CORNER OF LEFT WING OF BLDG 1 TO XFMR LOCATION; THREE 4" + TWO 1-1/4" AT & N 25' OF (QQ); ALL COMPLETE AND CONNECTED TO 30' N OF (QQ); ONE 3/4" OUTSIDE OF CURB FROM (RR) TO (SS); TWO 3/4" FROM (T) TO (Q); ONE 3/4" FROM (Q) TO (TT); ONE 3/4" IN ISLAND AT (K); ONE 3/4" FROM (T) TO NEAR (F); PIPING CONNECTIONS AND RISERS AT LOCATION FOR QUAZITE BOX BETWEEN GARAGES AT (Q) AND RISERS TO BOTH GARAGES; ONE 1-1/4" + ONE 3/4" FROM (X) TO S END OF GARAGE; ONE 3/4" FROM (X) TO 25' S FOR CARPORT; ONE 3/4" @ (UU) FROM GARAGE TO GARAGE; ONE 3/4" FROM NW CORNER OF BLDG 1 TO 25' N, THEN ONE 3/4' WEST ~60'; ONE 3/4' FROM (WW) WEST, THEN NORTH TO (XX); FROM (XX) TO 260' NORTH;

LOCATIONS (X) REFERENCED ARE NOTED ON INSPECTOR'S COPY OF SITE ELECTRICAL PLAN.

**Comments:**