



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192023	Date:	September 20, 2019
Project Title:	DOLLAR STORE	Applicant:	
Location:	869 SW LEMANS LN, LEES SUMMIT, MO 64082		ADVANTAGE FIRE PROTECTION SYSTEMS INC
Type of Work:			404 B NW 11TH ST
Occupancy Group:	M		BLUE SPRINGS, MO 64015
Description:	TENANT FINISH FOR RETAIL		
Construction Type:	Type VB (Unprotected)	Primary:	(816) 224-3400
Map Page:	215A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

(Informational Purposes)

System to be operational during construction.

Current annual sprinkler tag on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.