

# Inspection Summary

Permit #: PRSITE20180219, Development - Site  
MERIDIAN AT VIEW HIGH APARTMENTS  
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Base Lift	Steve Robbins	Partial	Friday, September 20, 2019

Informational

- 1 The base asphalt for the private street/parking lot has been installed up to building 9. This allows the fire dept. to get back there and get to a hydrant if needed. They are allowed to build vertical now. Steve Robbins 01/24/2019 4:49 PM

Informational

- 2 The base asphalt for the parking area up to building 9 was damaged over the winter months and due to all the fork lifts and the building that had been going on. O'Donnel Way Asphalt Company came in and did repairs to the base where needed and put in new base asphalt. We did spot proofrolls on this as I observed heavy trucks driving back and forth over a period of 3-4 weeks. They are ready for surface up to building 9.

DE - Commercial Curb Inspection	Steve Robbins	Partial	Friday, September 20, 2019
------------------------------------	---------------	---------	----------------------------------

Informational

- 1 The curbs for the parking lot up to building 9 have all been installed. Nothing from building 9-17 has been done.

Comments: