

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20171607

Address: 3520 SW HOLLYWOOD DR, Unit:G1, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mark Harding	Failed	Monday, September 23, 2019

Corrective Action Required:

1	Misc	-Install address 3520 G1
		-electrical incomplete panel not set from building 2.

Comments: