

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190346
Address: 4508 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Monday, September 23, 2019

Partial Correction:

1	Misc	**Final stabilization is needed for the yard **Range vent hood is not installed **Take off boots on round duct in basement are not sealed ** Duct work is not completed **Splash blocks need to be installed
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	**Range vent hood is not installed **Splash blocks need to be installed
---	--------------------------	--

Comments: