

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191238
Address: 306 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, September 23, 2019

Corrective Action Required:

1	Misc	SEAL FLOOR SINK TO FLOOR
---	------	--------------------------

Corrective Action Required:

2	Misc	CHECK ALL ELECTRICAL RECEPTACLES TO ENSURE ALL ARE MOUNTED SOLID TO BOX -- NONE "SOFT" OR LOOSE SIDE-TO-SIDE. USE YOKE SPACERS OR BOX EXTENDERS WHERE NEEDED.
---	------	---

Comments: