

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183809
Address: 4521 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Steve Quaid	Failed	Monday, September 23, 2019

Corrective Action Required:

1	Miscellaneous Correction	No access to structure sod, final grade, splash blocks - anti syphon devise needed for spicket in basement, water line needs to be secured mid way -irrigation permit needed and back flow test needs to be submitted to water department
---	--------------------------	--

Comments: