

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183928
Address: 1325 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, September 24, 2019

Corrective Action Required:

2	Misc	-Submit as-graded plot plan -Obtain awn irrigation permit -Uncover the sewer manhole -Install sewer tracer box with wire connected -Receptacle at AC not gfci-protected -Cedar posts buried in soil -Install breaker lock for hood -Screw door embedded braces into studs
---	------	--

Comments: