

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, September 25, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY TRENCHED ELECTRICAL CONDUIT AT: THREE 4" + TWO 1-1/4" TO (A); SAME CLUSTER OF CODUIT APPROVED 140 FEET SOUTH TO 90 EAST TO (C); + 50' EAST TO (E); THREE 4" FROM (C) TO (D); THREE 4" + TWO 1-1/4" FROM (E) TO (F); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (F) TO (G); ONE 1-1/4" FROM (H) TO (I); ONE 1-1/4" + TWO 3/4" FROM (I) TO (J); ONE 3/4" STUBBED EAST FROM (J); TWO 3/4" FROM (J) TO (K); TWO 3/4" FROM (K) TO (L); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + TWO 3/4" FROM (M) TO (N) WITH ONE STUBBED WEST AT (M) FOR SITE LIGHTING; TWO 4" + TWO 1-1/4" + ONE 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (N) TO (P); TWO 1-1/4" + ONE 3/4" FROM (Q) TO (S); ONE 3/4" FROM (Q) TO (R); ONE 3/4" FROM (T) TO (U); 3/4" CONDUIT AT CONSTRUCTION ENTRANCE APPROVED; 3/4" CONDUIT 110 FEET FROM SE CORNER OF THE BUILDING; REMAINDER OF RUN TO VAULT AT (W); THREE 4" + TWO 1-1/4" FROM (M) TO (X); THREE 4" + THREE 1-1/4" FROM (X) TO (Y); FOUR 4" + ONE 3" FROM (Z) TO (AA); ONE 3/4" AT ISLAND @ (W); ONE 3/4" FROM (X) TO (BB); ONE 3/4" (FROM (X) TO (CC); FOUR 4" + ONE 3" FROM (CC) TO (DD); THREE 4" + TWO 1-1/4" FROM (EE) TO (FF); TWO 3/4" FROM (GG) TO (HH); ONE 1-1/4" + ONE 3/4" FROM (HH) TO 60' WEST @ (II); THREE 4" + ONE 1-1/4" FROM (JJ) TO (KK); THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (MM) - THEN 30' EAST; THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (NN) 60' SOUTH; THREE 4" + ONE 1-1/4" ORIGINATING FROM (KK) EXTENDED TO (NN);

REMAINDER OF CONDUITS FROM E/SE CONVERGING ON LOCATION OF BOX TO BE INSTALLED AT (II); FOUR 4" + ONE 3" FROM XFMR LOCATION TO W END OF BLDG 4; THREE 4" FROM E END OF BLDG 4 NORTH 35', THEN S 15' TO (OO); FROM MONUMENT SIGN AT NORTH ENTRANCE TWO 3/4" TO 30' SE & TWO 3/4" TO 30' SW; FOUR 4" + ONE 3" FROM (OO) TO (PP) & SECONDARY CONDUITS AT (PP); THREE 4" + TWO 1-1/4" FROM (A) TO 24' N; FOUR 4" + ON 3" FROM NW CORNER OF LEFT WING OF BLDG 1 TO XFMR LOCATION; THREE 4" + TWO 1-1/4" AT & N 25' OF (QQ); ALL COMPLETE AND CONNECTED TO 30' N OF (QQ); ONE 3/4" OUTSIDE OF CURB FROM (RR) TO (SS); TWO 3/4" FROM (T) TO (Q); ONE 3/4" FROM (Q) TO (TT); ONE 3/4" IN ISLAND AT (K); ONE 3/4" FROM (T) TO NEAR (F); PIPING CONNECTIONS AND RISERS AT LOCATION FOR QUARTZITE BOX BETWEEN GARAGES AT (Q) AND RISERS TO BOTH GARAGES; ONE 1-1/4" + ONE 3/4" FROM (X) TO S END OF GARAGE; ONE 3/4" FROM (X) TO 25' S FOR CARPORT; ONE 3/4" @ (UU) FROM GARAGE TO GARAGE; ONE 3/4" FROM NW CORNER OF BLDG 1 TO 25' N, THEN ONE 3/4" WEST ~60'; ONE 3/4" FROM (WW) WEST, THEN NORTH TO (XX); ONE 3/4" FROM (XX) TO 260' NORTH, THEN TO (YY); TWO 3/4" FROM (YY) TO (CC); **ONE 1-1/4" FROM NW CORNER TO NE CORNER OF DUMPSTER ENCLOSURE;**

LOCATIONS (X) REFERENCED ARE NOTED ON INSPECTOR'S COPY OF SITE ELECTRICAL PLAN.

Comments: