

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183200  
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Failed	Wednesday, September 25, 2019

Partial Correction:

1	Misc	POST-MOUNTED TEMPORARY ELECTRICAL SERVICE AT WEST FENCE OK FOR USE
Corrective Action Required:		
2	Misc	<b>SHEETS APPARENTLY MISSING FROM APPROVED DRAWING SET. STAMPED SHEET E4.1 NOT FOUND.</b>

**Comments:**