

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191541
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	John Borns	Passed	Thursday, September 26, 2019

Comments: OK TO COVER WHEN READY GREASE INTERCEPTOR AND PIPING, WITH CLEANOUTS, FROM BUILDING ENTRY TO TANK.