

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190262
Address: 4517 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	Marquelle Williams	Partial	Thursday, September 26, 2019

Informational:
1 Misc SEPTEMBER 26, 2019
PRE POUR INSPECTION
SIDEWALK

Upon arrival, all forms appear to be within Lees Summit and ADA spec. There has been gravel installed. The gravel is the correct size and it is compacted.

Comments: