

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, September 26, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY UNDERGROUND CONDUIT: FROM BUILDING ENTRY
AT W END OF BLDG TO XFRMR LOCATION + CONDUIT FOR FUTURE TO 10' WEST

Comments: