

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190276

Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, September 26, 2019

Partial Correction:

1 Misc

ROUGH-PLUMBING OK:

-ROOF DRAIN

-ROUGH PLUMBING FOR RESTROOMS AT SW CORNER ON BOTH FLOORS

-4" WASTE AND VENT STACKS

Comments: