

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170399

Address: 3520 SW HOLLYWOOD DR, Unit:2, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Brandon Kalwei	Partial	Thursday, September 26, 2019

Corrective Action Required:

1	Misc	Above ceiling is approved for building #2
---	------	---

Comments: