



PLAN REVIEW CONDITIONS

September 27, 2019

B & A ARCHITECTURE
100 W 31ST ST STE 100
KANSAS CITY, MO 64108

Permit No: PRCOM20192576
Project Title: HAWTHORNE RIDGE CLUBHOUSE AND POOL
Project Address: 1534 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082
Parcel Number: 69620020200000000
Location: HAWTHORN RIDGE 1ST PLAT, LOTS 1 THRU 100, INCLUSIVE AND TRACTS A, B, C, D & E---TRACT C
Type of Work: NEW COMMERCIAL
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: CLUBHOUSE POOL AND SHADE STRUCTURE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

(Verified At Inspection)

Post occupant load signs in clubhouse and outside in the pool area. 45 in Clubhouse. 211 in pool area

2. 2018 IFC 407.2- Material Safety Data Sheets. Material Safety Data Sheets (MSDS) for all hazardous materials shall be readily available on the premises.

(Verified At Inspection)

3. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7

mm).

(Verified At Inspection)

4. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide 1 2A10BC extinguisher in clubhouse and 1 2A10BC extinguisher in the pool area.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

9/26/19 - acknowledged in letter

2. For the Health Department review contact Amanda Burch with the Jackson County Public Works Department, Environmental Services Division, at (816) 797-7198. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes.

9/26/19 - acknowledged in letter

3. For the Health Department inspection contact Amanda Burch with the Jackson County Public Works Department, Environmental Health Division at (816) 797-7198. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

9/26/19 - acknowledged in letter

5. Copies of the engineered roof truss package and shade structure were not provided at the time of permit application.

Action required: Provide roof truss and shade structure plans or request deferral.

9/26/19 - deferred

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.