

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191386
Address: 2601 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Friday, September 27, 2019

Corrective Action Required:

1	Misc	-fix erosion control around the lot -Protect electrical in west corner of garage and middle column in garage -add stud to NE kitchen wall for siding seam -secure gas line for fireplace -protect 3" piping and waterline at top and bottom plate, NW wall in living room. And strap top and bottom plate -missing joists hangers on SW side of garage -no plans on site
---	------	--

Comments: