

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191204
Address: 1809 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Monday, September 30, 2019

Corrective Action Required:

1	Misc	-Clean up street and re establish erosion control - fire block at top plate, dead space on the left side of garage door entrance into house -double joist hanger needed above fireplace -support gas line along west wall in basement -green bonding screw needed in panel -no gauge for gas line Ok to insulate
---	------	--

Comments: