CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191007

Address: 1844 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Steve Quaid Failed Tuesday, October 01,

Residential 2019

Corrective Action Required:

1 Misc ** Draft stop at fireplace

** Draft stop from garage to living area

** Main floor 1/2 bath - protect outlet in HVAC duct bay
** Main floor - Missing triple studs each side of stairs

** Bolt down columns in basement

Comments: