

Inspection Summary

Permit #: PRCOM20191541, Building Permit - Commercial
MARTIN CITY PIZZA & TAPS
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	Steve Robbins	Passed	Monday, September 30, 2019

Informational

1 The new 4" fire sprinkler service line was connected to the existing 6" private fire line and was ran to the building . 2 thrust blocks were poured and rock was installed and then backfilled.

Sewer Service Inspection - Commercial	Steve Robbins	Passed	Monday, September 30, 2019
---------------------------------------	---------------	--------	----------------------------

Informational

1 The sanitary line was cut at the main and a wye was installed with a fernco stainless steel hardback and tracer wire.
The anode was also installed at the wye and pipe ran to the grease trap.

Comments: