

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081500 NW PRYOR RD, LEES SUMMIT, MO 64081450
NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Abandonment	Ronald Paynter	Partial	Tuesday, October 01, 2019

Informational:

1 Misc

Redford severed the water line going to 500 Pryor. They capped it using mega lugs and poured a straddle block over the remaining section of active water line. They will return next week once the gas line has been removed to remove the remaining section of dead water line and fire hydrant. RP
10-1-19

Comments: