CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182092

Address: 1611 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Steve Quaid Failed Wednesday, October

Residential 02, 2019

Partial Correction:

1 Misc - Seal all outside electrical fixtures, penetrations, etc

- gfci in garage not working properly

- hammer arrestors needed for clothes washer

- C/o detector needed outside of downstairs bedrooms, need to Verify that

upstairs detectors are C/o as well

- gfci outlets in jack and Jill bathroom in basement are not working properly

- need to Sheetrock underneath stairs in unfinished basement

-outside GFCI by ac unit not working properly

Corrective Action Required:

2 Misc - Seal all outside electrical fixtures, penetrations, etc

- hammer arrestors needed for clothes washer

Comments: