

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191892
Address: 2807 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	John Borns	Passed	Wednesday, October 02, 2019

**Comments: NO ISSUES FOUND ON INSTALLATION OF PV SYSTEM. CLOSE PERMIT.
NOTE: BURIED FEEDER CONDUIT AND CABLE INSTALLED PREVIOUSLY WAS NOT REQUESTED FOR INSPECTION
AND HAS NOT BEEN APPROVED.**