

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181580
Address: 2532 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Wednesday, October 02, 2019

Corrective Action Required:

1	Misc	-handrail on deck needs to be code compliant, 2x6 not allowed -microwave and oven need to have lockout devices on breakers if hard wired -seal all outside light fixtures, penetrations, etc.
---	------	---

Comments: