

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191819
Address: 1208 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, October 03, 2019

Corrective Action Required:

1 Misc

FRAMING:

- Toe nail basement joists to sill plates
- Install full support underneath trimmer studs below fireplace

MECHANICAL:

- Fasten fireplace to framing
- Seal return air space above basement bathroom (at solid blocking above I beam)

****OK TO INSULATE**

Comments: