



September 25, 2019

Adam Murry
Engineering Solutions
50 S.E. 30th Street
Lee's Summit, MO 64082

RE: Hawthorn Ridge First Plat
Lot 42 Minimum Building Opening Elevation

Dear Mr. Murry,

Based on review of the Minimum Building Opening Elevation (MBOE) for Lot 42, provided on the Master Drainage Plan of the Hawthorn Ridge First Plat Street & Storm Sewer Plans, it is permissible to lower the right rear MBOE from an elevation of 1023.25 to 1020.72.

If you have any questions or need additional information, please don't hesitate to contact me by phone at 816.361.1177.

Sincerely,
Olsson

A handwritten signature in cursive script that reads "Melissa G. DeGonia".

Melissa G. DeGonia, P.E.
Project Engineer

