

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172500
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, October 04, 2019

Corrective Action Required:

1	Misc	Pending approval from other departments for TCO Codes, Fire , water ok for tco.
		Approved to stock, install permanent furniture and fixtures, tables chairs etc.
		NOT APPROVED FOR OCCUPANCY. NOT TO BE OPEN TO THE PUBLIC.
		See other departments on separate covers. Pool on separate permit. Lower level patio, access to pool room, pool deck incomplete at this inspection.

Comments: