CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190741

Address: 2520 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mark Harding Failed Monday, October 07,

Residential 2019

Corrective Action Required:

1 Misc - fire stop basement bedroom on north wall over window from fur down.

-install 3 studs in basement wall see plans.

--install 3/4" plywood for fire stopping over fire plans and dead spaces.

--flue clearance basement wall tp plywood and framing

--

Comments: