

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20174026
Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	John Jackson	Partial	Monday, September 16, 2019

Informational:

1 Misc

Contractor installed 55' of 18" HPDE storm pipe.
1/15" Nyloplast Drain Basin @ 10e and 2/24" Nyloplast Drain Basin @ 10F & 10G. 9/11/19

Informational:

2 Misc

Comments: