

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191001
Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	Brandon Kalwei	Partial	Tuesday, October 08, 2019

Informational:
1 Misc All exterior wall electrical boxes are approved, need to cover ASAP as the MC lines are not rated to be outside in the weather, rain, etc. ok to cover

Comments: