



**PLAN REVIEW CONDITIONS**

October 08, 2019

ACI BOLAND  
1421 EAST 104TH ST; SUITE 100  
KANSAS CITY, MO 64131

Permit No: PRCOM20192572  
Project Title: LEE'S SUMMIT MEDICAL CENTER - MEDICAL SUITES ON 1ST AND 3RD FLOORS  
Project Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063  
Parcel Number: 60420990900000000  
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A  
Type of Work: NEW TENANT FINISH  
Occupancy Group: BUSINESS  
Description: TENANT FINISH FOR MEDICAL OFFICES  
ASSIGNED SUITES:  
1100 - Bariatric  
1200 - Neuro  
1300 - GI  
3100 - Cardiology  
3200 - Surgery Clinic  
3300 - Imaging

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Approved with Conditions**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. (Action Required)

Any modifications to the alarm system, provide three sets of PE stamped shop drawings.

2. 2018 IFC 407.3- Identification. Individual containers of hazardous materials, cartons or packages shall be marked or labeled in accordance with applicable federal regulations. Buildings, rooms and spaces

containing hazardous materials shall be identified by hazard warning signs in accordance with Section 2703.5.

(Verified At Inspection)

Label all rooms

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the sprinkler system, provide three sets of PE stamped shop drawings.

4. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

1. The permit for these suites is tied to an incomplete shell. Occupancy for the suites will not be granted until occupancy for shell has been granted.

Action required: Comment is for informational purposes.

10/8/19 - Acknowledged in letter

2. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is for informational purposes.

10/8/19 - Acknowledged in letter

3. This structure has been assigned one address. All suites/apartments shall be assigned an address by the owner which can be numeric, alphabetic or a combination of both. If the building has multiple stories the suite/apartment number shall start with a number representing the floor on which the unit is located.

Action required: Comment is for informational purposes. This building has been assigned the address of 1980 SE Blue Pkwy. Please update your records.

The suites have been assigned the following numbers:

1100 - Bariatric

1200 - Neuro

1300 - GI

3100 - Cardiology

3200 - Surgery Clinic

3300 - Imaging

10/8/19 - Acknowledged in letter

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***