

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182609  
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, October 10, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

NORTH STAIRWELL:

BASEMENT LEVEL: 1ST LAYER AT INTERIOR + BETWEEN JOISTS AT BACKSIDE;  
2ND LAYER;

1ST FLOOR: 1ST LAYER; **2ND LAYER**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

SOUTH STAIRWELL:

1ST FLOOR: 1ST LAYER; **2ND LAYER**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRECAULK.

**Comments:**