

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20181645**
Address: **2509 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082**
Inspected On: **Friday, October 11, 2019**
Inspected By: **Brandon Kalwei**
Expiration Date: **10/25/2019 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Temporary C of O	Friday, October 11, 2019

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Drain line for dishwasher cannot be located at bottom of cabinet, needs to be located to top of cabinet- second locking devise needed for rear sliding door- window screens need to be installed- replace broken splash block on west NW corner- clean up side walk of mud |
|---|------|--|