

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191578
Address: 1804 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Steve Quaid	Failed	Friday, October 11, 2019

Corrective Action Required:

1	Misc	** Main floor 1/2 bath vent duct is not connected
		** Draft stop plumbing from 1st to 2nd floor in HVAC box out

Comments: