

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191609
Address: 2915 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Steve Quaid	Failed	Friday, October 11, 2019

Partial Correction:

1	Misc	** Garage braced wall panels exterior straps are missing fasteners
		** Master bath vent fan duct has come off of vent.

Corrective Action Required:

2	Misc	** Garage braced wall panels exterior straps are missing fasteners
---	------	--

Comments: