

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172505
Address: 209 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, October 11, 2019

Corrective Action Required:

1	Misc	Codes- 1. Label disconnects permanently 1 of 2, 2 of 2. 2. Fire caulk all 1st floor units at ac line in furnace rooms. 3. Unit 311 deck railing . 4. Secure Ac disconnect supply within 12" of box . 5. Label all Ac disconnects with room numbers. 6. Secure conduit in sprinkler room. 7. Seal/ caulk all exterior lights where required, garage side at brick etc. See Fire Dept, Planning, and water on separate approval. No TCO will be issued until Substantial complete is approved for site permit.
---	------	---

Comments: