

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192571
Address: 436 NW CHIPMAN RD, Unit:ES, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Saturday, October 12, 2019

Partial Correction:

1 Misc

OK TO POUR WHEN READY LIGHT POLE BASES #2 - #12;

PER 10/9/2019 ENGINEER LETTER REQUIRED DEPTH BELOW GRADE HAS BEEN
REDUCED TO 6'.

Comments: