

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191541
Address: 354 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Monday, October 14, 2019

Corrective Action Required:

1	Misc	LIGHT TEST APPROVED ON SHOP WELDS ON A TWO-SECTION GREASE DUCT. CALL FOR INSPECTION OF FIELD WELDS BEFORE WRAP IS APPLIED
---	------	--

Comments: